

From: [Foi Enquiries](#)
To: [REDACTED]
Subject: EIR-17-1457 - Inspection - Porthill Court
Date: 01 November 2017 11:34:35
Attachments: [Further Information - Right to Review & Appeal.pdf](#)
[Map of Porthill Court png \(348265\).png](#)
[EIR-17-1457 - Porthill Court - Maintenance Records 14 Jan 2016-20 Oct 2017.pdf](#)

Dear [REDACTED],

Thank you for your information request of 12 October 2017. Aberdeen City Council (ACC) has completed the necessary search for the information requested.

Please refer to the accompanying map of “the relevant area”. The exact location in respect of which we are seeking the relevant records is the internal communal staircase that serves, amongst others, 8 Porthill Court, Aberdeen.

Records of inspection relating to Porthill Court, Aberdeen (“the relevant area”) covering the period 14/01/2016 to date.

Maintenance records including records of independent contractors working in the relevant area over the said period.

Repair records attached for the specified period.

Records of complaints about the condition of the relevant area over the said period.

No complaints were logged regarding the condition of Porthill Court between 14/01/16 to date.

For clarity, a complaint is defined as an expression of dissatisfaction regarding our actions, or lack of action, or the standard of service provided by us or on our behalf. There are some topics that cannot be considered as a “complaint”, including first time service requests such as reporting potholes or pavement defects. For more information, please visit:

http://www.aberdeencity.gov.uk/council_government/feedback_complaints/crc_whatisacomplaint.asp

Records of any residents suffering accidents which have occurred in the relevant area over the said period.

We have only been advised of one incident for the specified period. This was a trip on the communal staircase. The incident date was given as 14 January 2017.

Please note that third party names and personal details, as well as the names of ACC Officers who are below Head of Service level have been redacted (blacked out) from the attached report. This is because ACC considers that this information is excepted from disclosure. In order to comply with its obligations under the terms of Regulation 13 of the EIRs, ACC hereby give notice that we are refusing your request under the terms of Regulation 11(2) in conjunction with Regulation 11(3)(a)(i) – Personal Information - of the EIRs.

In making this decision ACC considered the following points:

ACC is of the opinion that Regulation 11(2) applies to the information specified above as the information in question is personal information relating to living individuals, and the applicant is not the data subject.

ACC is of the opinion that Regulation 11(3)(a)(i) applies, as ACC considers that disclosure of this

information would be a breach of the first Data Protection Principle (that personal information must be processed fairly and lawfully) and second Data Protection Principle (personal information must only be processed for a specific and lawful purpose). ACC Officers who are below Head of Service level and third parties named within the attached document would not expect ACC to release this information about them into the public domain under the EIRs (or the Freedom of Information (Scotland) Act 2002 (FOISA)).

We hope this helps with your request.

Yours sincerely,

Information Compliance Team

INFORMATION ABOUT THE HANDLING OF YOUR REQUEST

As the information which you requested is environmental information, as defined under Regulation 2(1) of the Environmental Information (Scotland) Regulations 2004 (the EIRs), ACC considered that it was exempt from release through FOISA, and must therefore give you notice that we are refusing your request under Section 39(2) of FOISA (Freedom of Information (Scotland) Act 2002). However, you have a separate right to access the information which you have requested under Regulation 5 of the EIRs, under which ACC has handled your request. Please refer to the attached PDF for more information about your rights under the EIRs.

Information Compliance Team
Customer Service
Corporate Governance
Aberdeen City Council
3rd Floor North
Business Hub 17
Marischal College
Broad Street
ABERDEEN AB10 1AQ

foienquiries@aberdeencity.gov.uk

Tel 03000 200 292

*03000 numbers are free to call if you have 'free minutes' included in your mobile call plan.
Calls from BT landlines will be charged at the local call rate of 10.24p per minute (the same as 01224s).

www.aberdeencity.gov.uk

Job Ref	Type	Priority	Short Description	Received Date	Address
6252207	22	PL24	MANUFACTURE/FIT BRACKETS TO SECURE LADDER IN PLACE	16/10/2017 15:04:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6235591	25	NE5	3RD FLOOR - CORRIDOR DOOR BROKEN GLASS BOTTOM PANEL - RENEW	12/10/2017 14:07:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6204985	51	I3	POST INSPECTION OF 5843408.	06/10/2017 11:14:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6148257	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	01/10/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6146500	20	PL24	GENERATOR MAINTENANCE	01/10/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6145714	56	PL24	ADL - LIFTS MONTH SERV FACT	01/10/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6150070	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/10/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6149540	56	E4	ADL - Communal: Lifts; Block Affected;	28/09/2017 11:13:13	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6114248	51	I3	POST INSPECTION OF 5846624.	22/09/2017 11:02:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6114230	51	I3	POST INSPECTION OF 5843670.	22/09/2017 11:01:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6112868	56	H3	R B WILSON FOBS SUPPLY 40 AND DELIVER TO MARISCHAL COLLEGE QUEEN STREET ENTRANCE BUZZ AT BARRIER FOR ACCESS Communal: Communal lighting; Communal lighting - not working; landing of 5th floor; Only one light affected; Floor(s) affected; 5th floor landing; Fair wear and tear Reported by tenant at flat tel	22/09/2017 09:48:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6110116	12	NE5	COMMUNAL - RUB DOWN AND REPAINT TUBULAR HANDRAILS AND METAL BALLARDS SEE PHOTO'S	21/09/2017 15:45:54	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6105813	15	PL24	COMMUNAL - GROUND FLOOR FOYER REMOVE EVAC BOX AND CHAIR.	21/09/2017 10:16:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6100420	13	NE5	SUPPLY AND FIT 5 No TAMPERPROOF LOCKABLE NOTICE BOARD FOR FIRE SIGNS	20/09/2017 13:07:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6097154	13	PL90	CHUTE LID OFF IN CHUTE ROOM ON 5TH FLOOR - AS PER E-MAIL FROM ORBIS	20/09/2017 10:27:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6096841	18	NE5	POST INSPECTION	20/09/2017 09:54:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6034046	51	I3	Communal: Laundry Facilities; Tumble Drier; tumble driers reported by	08/09/2017 11:44:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6020571	12	NE5	3 driers not working and 1 not accepting card.	06/09/2017 13:04:37	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
6003567	56	H3	Communal: CCTV Cameras; Camera 13 - no image; SPIE	04/09/2017 08:55:07	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5967199	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/09/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5965755	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	01/09/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5963980	20	PL24	GENERATOR MAINTENANCE	01/09/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5963074	22	PL24	LIFTS MONTH SERV FACT	01/09/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5992335	15	PL24	EXTERNAL CELLER DOOR GROUND FLOOR PAINT DOOR IN THE UNDERPASS AT SIDE OF BUILDING.	31/08/2017 14:17:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5933542	17	PL24	CHECK DRY RISERS	23/08/2017 10:26:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5929457	56	U24	Communal: TV reception/Aerial; Missing only some channels; Problem occurs all the time; missing channel and poor picture quality ; if fault found to be from Tenant's (TV, aerial lead or freeview box); Contractor to inform ACC of details and if tenant rech	22/08/2017 13:08:59	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5911297	22	E4	Communal: Lifts; Block Affected; ; Lift serves all floors; People are stuck in lift phoned through to	18/08/2017 09:58:57	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5846896	51	I3	POST INSPECTION OF 5449964.	04/08/2017 14:46:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5846624	18	PL24	COMMUNAL: RENDER AT CELLAR OF 65 TO BE REPAIRED	04/08/2017 14:38:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5845652	56	H3	Communal: Door Entry System; Cannot hear visitors; Check intercom and handset; Block affected; ; Fair wear and tear reported by , all the residents on top floor can't hear visitors on intercom.	04/08/2017 14:08:21	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5844754	13	PL24	COMMUNAL: 7TH FLOOR - NEW FLAT NUMBERS IN STAIR AREA REQUIRED	04/08/2017 13:31:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5844730	13	PL24	COMMUNAL: 1ST FLOOR - REPAIR WINDOW VENT OUTSIDE FLAT 5, 3RD FLOOR - WINDOW OUTSIDE LIFTS NEEDS TO BE SECURED/LOCKED	04/08/2017 13:28:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5844715	16	PL24	COMMUNAL: 4TH FLOOR - DUMMY LANDING SMALL HOLES ON WALLS, 7TH FLOOR - PLASTER WORK REQUIRED TO WALLS ON STAIR	04/08/2017 13:26:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5844698	15	PL24	COMMUNAL: GROUND FLOOR - FLOORING UPSTAND NEEDS PAINTED, 7TH FLOOR - PAINT WORK REQUIRED TO WALLS ON STAIR	04/08/2017 13:23:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5844673	25	PL24	COMMUNAL: 1ST FLOOR - GLASS DOOR TO VERANDA NEEDS TO BE REPAIRED, GLASS OUTSIDE 12 + 13 BROKEN, 4TH FLOOR GLASS CRACKED ON DOOR TO DUMMY LANDING BOTTOM PANE	04/08/2017 11:57:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5843895	13	PL24	COMMUNAL: 2ND FLOOR - BOTH DOORS SERCURED UNTIL RECOMMENDATION FOR NEW DOORS FROM H&S TEAM	04/08/2017 11:49:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5843750	13	PL24	COMMUNAL: 1ST FLOOR - RENEW ELECTRIC MAINS CUPBOARD DOORS AND LOCKS, 9TH FLOOR - NEW DOOR REQUIRED LEADING TO 65-68	04/08/2017 11:45:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5843711	13	PL24	COMMUNAL: GROUND FLOOR - HANDLE LOOSE ON DOOR TO MAIN ENTRANCE, 5TH FLOOR - PUSH PLATE REQUIRED ON DOOR 33 - 40	04/08/2017 11:42:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5843670	13	PL24	COMMUNAL: GROUND FLOOR FIRE DOOR TWISTED, 1ST FLOOR BEADING ON BOTTOM PAIN OF DOOR LEADING TO 1 - 8 MISSING, 7TH FLOOR - DOOR TO STAIR TWISTED	04/08/2017 11:38:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5843616	13	PL24	COMMUNAL:GROUND FLOOR - RUBBER FLOOR TILES LIFTING AT STAIR, 7TH FLOOR - CARPET WORN ON STAIR TO 60 + 61	04/08/2017 11:35:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5843528	12	PL24	COMMUNAL: 3RD FLOOR - LOOSE WIRE OUTSIDE 28 -29	04/08/2017 11:33:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D

5843486	12	PL24	COMMUNAL: 5TH FLOOR - LIGHT OUT AT 38, 6TH FLOOR LIGHT OUT IN STAIR	04/08/2017 11:29:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5843415	11	PL24	COMMUNAL: 8TH FLOOR - METAL WINDOW IN STARI NEEDS REPAIRED	04/08/2017 11:27:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5843408	11	PL24	COMMUNAL: RENEW RAILING ON ACCESS RAMP	04/08/2017 11:24:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5825397	56	H3	Communal: TV reception/Aerial; Problem occurs all the time; NO RECEPTION TO SEVERAL TVS IN BUILDING; If fault found to be from Tenant's (TV, aerial lead or freeview box); Contractor to inform ACC of details and if tenant rechargeable on invoice	01/08/2017 18:59:02	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5784215	56	PL24	ADL LIFTS MONTH SERV FACT	01/08/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5785226	20	PL24	GENERATOR MAINTENANCE	01/08/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5785610	12	PL90	PUMP MAINTENANCE	01/08/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5785770	20	PL90	PUMP MAINTENANCE	01/08/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5786100	12	PL90	FAN SERVICING	01/08/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5786300	20	PL90	FAN SERVICING	01/08/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5790280	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/08/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5787953	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	01/08/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5775570	56	E4	ADL - Communal: Lifts; Block Affected; porthill court; Lift serves all floors; stuck on ground floor Reported by from Orbis.	25/07/2017 08:39:22	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5767923	12	PL24	COMMUNAL - LIGHT OUT OUTSIDE FLAT NUMBER	22/07/2017 09:47:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5750171	56	U24	Communal: TV reception/Aerial; Missing All Channels; Problem occurs all the time; No signal; If fault found to be from Tenant's (TV, aerial lead or freeview box); Contractor to inform ACC of details and if tenant rechargeable on invoice Reported by flat	20/07/2017 08:55:56	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5721594	51	I3	POST INSPECTION OF 5325828.	14/07/2017 10:29:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5710016	56	H3	Communal: Door Entry System; Cannot hear visitors; Check intercom and handset; Block affected; ; Fair wear and tear Cannot hear visitors at flat handset. Reported by tenant tel:	12/07/2017 15:03:05	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5709193	56	E4	Communal: Door Entry System; main entrance intercom unit; intercom not working; Block affected; 69 - 70 - 71 - 72; Fair wear and tear REPORTED BY FLAT CONTACT NUMBER - CALLER STATES THIS IS AN ON GOING PROBLEM	12/07/2017 14:19:57	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5689912	13	NE5	ASSIST LANES FOR DRAINS IN REPAIR LEAK AT UNDERPASS	07/07/2017 10:44:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5683981	14	PL24	ERECT ZIP UP SCAFFOLD AT UNDERPASS TO ASSIST LANES FOR DRAINS	06/07/2017 12:39:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5592667	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/07/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5584048	56	PL24	EMERGENCY LIGHTING YEARLY SERVICING	01/07/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5581858	20	PL24	GENERATOR MAINTENANCE	01/07/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5580893	56	PL24	ADL LIFTS MONTH SERV FACT	01/07/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5620880	11	H3	REFIX CAST IRON PIPE AT UNDER PASS AS PER PLUMBER	27/06/2017 10:35:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5593276	56	H3	Communal: Door Entry System; main entrance intercom unit; intercom not working; Block affected; 9th floor - all tenants on top floor - no intercoms working - 69-72; Fair wear and tear reported by	21/06/2017 13:43:10	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5588878	56	E4	Communal: CCTV Cameras; CAM 3 AND CAM 7 LOOKING AT THE GROUND	21/06/2017 10:57:26	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5588194	13	NE5	COMMUNAL - CLEANERS CUPBOARD - KEYS LOCKED INSIDE - OPEN AND PUT KEYS IN KEYSAFE	21/06/2017 10:35:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5581960	14	R10	27/06 AM - BUILD ZIP UP SCAFFOLD FOR PLUMBER + JOINER TO ASSESS + REPAIR WATER PEN AT R H SIDE OF UNDER PASS	21/06/2017 08:20:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5581375	13	R10	27/06 AM- ASSIST PLUMBER FOR ACCESS TO UNDER PASS FOR LEEK GOING INTO COMMUNAL AREA , TOTAL ESTIMATE £ 1000	21/06/2017 08:16:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5581199	17	R10	27/06 - FAO - INVESTIGATE WATER LEAK AT UNDER PASS AT R H SIDE OF BUILDING ZIP UP SCAFFOLD REQUIRED , ESTIMATE £1000 TOTAL	21/06/2017 08:13:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5577120	12	H3	COMMUNAL - ASSIST SSE ENGINEER FOR ELECTRICAL METERS	20/06/2017 13:21:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5561377	15	E4	Communal: Graffiti; colour; black; external wall; Natural roughcast FAO : Graffiti Removal service,		
			Reference No : GRAFFITI3123 Site (Street/Park/etc) : Porthill court Location : On one of struts down towards car park Locational Details : In front of hou	16/06/2017 11:27:17	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5556714	56	E4OOH	Specialist Cleaning: Specialist Cleaning Required; LARGE AMOUNT OF WATER AFTER HEAVY DOWNPOUR reported BY @NO - TEL.	15/06/2017 16:46:44	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5556577	50	I3	FOLLOW ON JOB: For OOH Temporary repairs; Original Job No.; 5556506; RAIN WATER LEAKING - GROUND FLOOR; IF NOT REPAIRABLE THEN PLEASE RENEW; Fair wear and tear	15/06/2017 16:26:28	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5556513	12	E4OOH	REPORTED BY FLAT CONTACT NUMBER RAIN WATER LEAKING ON TO THE LIGHT ON THE GROUND FLOOR - REPORTED BY FLAT CONTACT NUMBER	15/06/2017 16:21:47	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D

5556506	18	E4OOH	MAKE SAFE - RAIN WATER POURING DOWN FROM ROOF SPACE TO THE GROUND FLOOR NEAR THE LIFT - REPORTED BY FLAT CONTACT NUMBER	15/06/2017 16:20:14	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5528707	22	E4OOH	Communal: Lifts; Block Affected; Both; Both Lifts; Both lifts out of order	12/06/2017 06:03:56	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5859487	56	E4OOH	CONFIRMATION ADL WORK DONE 12/6/17. Both lifts out of service L/H lift car gate needed adjusted R/H lift was doors timed out and just needed reset.	12/06/2017 06:03:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5516010	56	E4	Communal: CCTV Cameras; DVR DOWN REPORTED BY TILLYDRONE CONTROL ROOM	08/06/2017 10:09:25	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5506758	17	E4	Pipes: Water pressure and supply; No water supply; Properties throughout Multi Storey affected No water from any cold taps. Reported by tenant	07/06/2017 10:08:26	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5482637	51	I3	POST INSPECTION OF 5115644.	02/06/2017 10:44:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5480453	11	U24	Communal: Window or safety bars; Safety bars / rail; someone has removed the screws from the bar which keeps the window closed Reported by Tillydrone Housing - window located on first floor on right hand side coming out of the lift.	02/06/2017 09:06:05	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5414239	56	PL24	ADL - LIFTS MONTH SERV FACT	01/06/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5415306	20	PL24	GENERATOR MAINTENANCE	01/06/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5418280	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	01/06/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5423347	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/06/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5460825	56	E4	ADL - FAO - L/H/L - NOT WORKING REPAIR AS REQUIRED Communal: Door Entry System; Cannot hear visitors; Check intercom and handset; Block affected; REPORTED BY	30/05/2017 11:40:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5455334	56	H3	OWNER AT FLAT Fair wear and tear NO SOUND FROM BUZZER OR VOICES	29/05/2017 13:43:20	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5450135	15	PL24	COMMUNAL - 5TH FLOOR OUTSIDE NUMBER 33 REPAINT WALL (LIKE FOR LIKE) AFTER PLASTERER	29/05/2017 09:12:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5449964	16	PL24	COMMUNAL - 5TH FLOOR OUTSIDE NUMBER 33 REMOVE ALL DAMAGED PLASTER AND REPAIR WALL (PHOTO'S)	29/05/2017 09:06:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5448985	25	U24	Glazing: Single glazing; THE VESTIBULE DOOR LEADING TO THE COMMUNAL SIDE EXTERNAL DOOR; obscure/patterned glass; wooden; smashed pane; Vandalism REPORTED BY (RES ASSOC)	29/05/2017 08:33:34	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5387555	56	E4	Communal: Door Entry System; Both doors not locking - property insecure REPORTED BY NO TEL	18/05/2017 11:53:18	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5371071	13	R10	CHECK ALL COMMUNAL BALCONY DOORS WITH MASTER KEY - PICK UP FROM 'S DESK	16/05/2017 08:36:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5340232	56	H3	Communal: Door Entry System; Cannot hear visitors; Check intercom and handset; Block affected; ; Fair wear and tear AT AND AT HAVING PROBLEMS CAN YOU ALSO CHECK HANDSETS REPORTED BY HOUSING TEL	09/05/2017 14:55:56	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5325835	12	NE5	COMMUNAL - 1ST FLOOR VARIOUS LIGHTS OUT AND DIFFUSERS BROKEN. GROUND FLOOR 1 LIGHT OUT AT LIFT FOYER AND DIFFUSER AT MAIN DOOR BROKEN.	06/05/2017 09:35:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5325828	12	PL24	COMMUNAL - 5TH FLOOR 1 BULB OUT IN LIGHT UNIT AT SERVICE CUPBOARD. REPLACE DIFFUSERS AT 44 - 45 AND OUTSIDE NUMBER 39. 3RD FLOOR VARIOUS LIGHTS OUT. JS/NW	06/05/2017 08:59:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5325747	12	R10	COMMUNAL - 8TH FLOOR STAIR LANDING LIGHT OUT, 7TH FLOOR LIGHT FITTING AT BIN CHUTE ROOM DIFFUSER BROKEN AND 1 BULB OUT IN LIGHT UNIT BESIDE FLAT NUMBER	06/05/2017 08:47:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5325715	13	NE5	COMMUNAL - DOOR ONTO ROOF LEFT HAND SIDE HAS BEEN VANDALISED REPAIR AS PER	06/05/2017 08:40:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5254886	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	02/05/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5249042	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	02/05/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5247091	20	PL24	GENERATOR MAINTENANCE	02/05/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5246267	56	PL24	ADL - LIFTS MONTH SERV FACT	02/05/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5289987	50	I3	(- NO ACTION) CAMERA IS MISSING FROM THE ROOF - TENANT STATES IT WAS REMOVED A YEAR AGO AND NOT REPLACED - REPORTED BY PORTHILL COURT	28/04/2017 16:59:54	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5289970	56	H3	Communal: Door Entry System; main entrance intercom unit; buzzers not working; Block affected; ; Fair wear and tear REPORTED BY FLAT 72	28/04/2017 16:50:09	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5288260	16	R10	COMMUNAL 7TH FLOOR CORRIDOR GABLE WALL REPLASTER SMALL HOLES JS/NW Communal: Unspecified communal repair; PROVIDE BOTTLED WATER TO FLATS 65-72; FLATS 65-72; ; NO WATER SUPPLY; ; 2 X 2L BOTTLES PER FLAT; ; IF NOT REPAIRABLE THEN PLEASE RENEW; Please advise supervisor of any work revisions; Fair wear and tear	28/04/2017 13:51:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5282082	18	E4OOH	Please adv	27/04/2017 21:42:09	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5282011	17	E4OOH	Pipes: Water pressure and supply; No water supply; Properties throughout Multi Storey affected REPORTED BY AT FLAT . TEL:	27/04/2017 20:22:59	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5281931	17	E4OOH	Pipes: Water pipe - leaking or burst; Yes - Operator to raise as C130; PLANT ROOM; water supply pipe; Turned water off; Electrical fittings not getting wet; Fair wear and tear	27/04/2017 19:09:34	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5281240	12	E4	No cold water at building	27/04/2017 15:54:33	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D

5244693	56	E4OOH	Fire alarm panel showing faults. Reported by	23/04/2017 11:15:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5240201	56	PL24	ADL - SHORTEN LIFT ROPES WITH	21/04/2017 11:11:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5240025	22	PL24	SHORTEN ROPES TO LIFT WITH ADL ENGINEER	21/04/2017 11:10:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5233570	12	H3	COMMUNAL LIGHTS - 2 X LIGHTS OUT IN FOYER - AS PER EMAIL ORBIS	20/04/2017 13:31:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5197852	51	I3	POST INSPECTION OF 4991149. Communal: Communal lighting; Communal lighting - broken; On the roof - one light not working. For access to the roof press 71 or 72.; bulkhead fitting; whole fitting; Only one light affected; Floor(s) affected; Light on the roof.; Fair wear and tear	13/04/2017 11:53:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5190198	12	NE5		12/04/2017 14:07:32	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5190173	56	H3	Communal: Door Entry System; main entrance intercom unit; buzzers not working; Block affected; All buzzers not working properly in the building. Resident at reported that the privacy button doesn't work and the buzzers are making a really hi	12/04/2017 14:05:28	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5150265	13	E4	Windows: Window catch - broken; 5TH FLOOR; wooden frame; unknown catch type; Fair wear and tear - REPORTED BY AT TEL -	05/04/2017 12:57:11	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5149879	56	H3	Communal: Door Entry System; Service button not working Not working in the morning. Reported by ORBIS	05/04/2017 12:13:57	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5141661	13	PL24	UNDERPASS - REMOVE BOARD ON CEILING AT HATCH CUT TO SIZE AND REFIT	04/04/2017 13:05:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5095574	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/04/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5082398	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	01/04/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5079997	20	PL24	GENERATOR MAINTENANCE	01/04/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5079066	56	PL24	ADL F.A.O. . LIFTS MONTH SERV FACT	01/04/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5115644	16	PL24	FAO - RECEMENTING CEILING ON UNDERPASS AS PER	30/03/2017 12:47:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5030275	12	NE5	Communal: Communal lighting; Communal lighting - not working; SIDE OF FLAT ON THE ROOF OF PORTHILL COURT; Only one light affected; Floor(s) affected; ON THE ROOF ON THE SIDE OF FLAT; Fair wear and tear REPORTED BY TENANT IN FLAT	17/03/2017 12:12:49	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
5030243	56	E4	Communal: Door Entry System; main entrance intercom unit; intercom not working; Block affected; PORTHILL COURT; Fair wear and tear TENANT IN FLAT HAS BEEN HAVING PROBLEMS SINCE CHRISTMAS, CANNOT HEAR VISITORS AND WHEN HE RELEASES THE DOOR TO ALLOW A	17/03/2017 12:11:05	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4999483	56	PL24	SPIE (SCOTSHIELD)- CONFIRMATION ONLY- PUT LOG BOOK IN BUILDING- DATE OF VISIT 01/02/2017	13/03/2017 14:32:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4991149	13	U24	(NO MATERIAL REQUIRED) COMMUNAL UNDERPASS - F	11/03/2017 08:21:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4981206	14	R10	(NO MATERIAL REQUIRED)- SUPPLY AND ER	09/03/2017 14:25:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4928246	56	E4	Communal: Door Entry System; Both doors not locking - property insecure Front and rear doors.	01/03/2017 09:50:23	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4876774	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/03/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4868701	56	PL24	ADL - LIFTS MONTH SERV FACT	01/03/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4869582	20	PL24	GENERATOR MAINTENANCE	01/03/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4871769	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	01/03/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4925728	56	E4OOH	RBWILSON - FRONT DOOR NOT LOCKING, PROPERTY INSECURE - REPORTED BY PROPERTY FACTOR - AT MARISHALL COLLEGE, EXTENSION	28/02/2017 18:36:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4918328	56	H3	ADL - LIFT NOT WORKING	28/02/2017 10:07:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4891608	56	E4	Communal: Door Entry System; Automated electric door closer not functioning correctly THE MAGNETS AT THE BOTTOM OF THE DOOR ARE NOT WORKING.REPORTED BY CITY WARDEN	23/02/2017 10:47:15	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4855860	13	NE5	REFIX CUPBOARD DOOR FOR EVAC CHAIR ON GROUND FLOOR, AND 7TH FLOOR DOOR CLOSER IS BROKEN.	17/02/2017 14:44:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4845149	56	E4	Communal: Door Entry System; main entrance intercom unit; intercom not working; Block affected; ; Fair wear and tear DOOR OPENING WHEN BUZZER PRESSED - Reported by, Orbis,	16/02/2017 12:57:18	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4819185	56	H3	CHUTE ROOM ON 7TH FLOOR HAS SINGLE BED FOR UPLIFT- AS PER EMAIL FROM ORBIS	13/02/2017 08:49:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4818576	12	H3	STAIRWELL LIGHTS OUT ON 7TH AND 5TH FLOOR- AS PER EMAIL FROM ORBIS	13/02/2017 08:21:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4816730	56	E4OOH	Specialist Cleaning: Specialist Cleaning Required; urine in right hand lift	11/02/2017 16:39:44	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4813120	12	NE5	Communal: Communal lighting; Communal lighting - not working; ALL THE LIGHTS ON THE 5TH FLOOR LANDING; Various lights throughout affected; Floor(s) affected; ; Fair wear and tear REPORTED BY WHO LIVES IN FLAT	10/02/2017 12:54:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4813063	56	E4OOH	CONFIRMATION WORK DONE 11/12/16. Communal: Lifts; Block Affected; Porthill Court; Both Lifts; Major water leak causing water to leak through lifts and lift electricals. Reported by chair of Resident's Association (EXTERNAL CONT)	10/02/2017 12:49:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4811154	12	NE5	Communal: Communal lighting; Communal lighting - not working; ALL THE LIGHTS ON THE 5TH FLOOR LANDING; Various lights throughout affected; Floor(s) affected; ; Fair wear and tear REPORTED BY WHO LIVES IN FLAT	10/02/2017 10:23:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D

4796090	56	H3	Communal: Door Entry System; main entrance intercom unit; buzzers not working; Block affected; Porthill Court; Fair wear and tear Buzzers, intercom and door locks not operating. Reported by tenant	08/02/2017 13:28:53	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4796050	13	NE5	Locks and Fittings: Door closer; broken; external door; timber door; door leading to the four roof flats on the 9th floor; overhead door closer; Fair wear and tear. Reported by tenant	08/02/2017 13:26:15	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4782360	18	E4	Communal: Refuse Chute blocked; floor; 1st floor up. Resident from Porthill Court reported it	07/02/2017 09:47:46	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4773492	12	NE5	Communal: Communal lighting; Communal lighting - not working; ALL THE LIGHTS ON THE 5TH FLOOR LANDING; Various lights throughout affected; Floor(s) affected; ; Fair wear and tear REPORTED BY WHO LIVES IN FLAT	06/02/2017 10:00:15	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4688356	20	PL90	FAN SERVICING	01/02/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4686180	56	PL24	ADL - FAO - LIFTS MONTH SERV FACT	01/02/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4687306	20	PL24	GENERATOR MAINTENANCE	01/02/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4687673	12	PL90	PUMP MAINTENANCE	01/02/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4687828	20	PL90	PUMP MAINTENANCE	01/02/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4694544	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/02/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4689825	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	01/02/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4688116	12	PL90	FAN SERVICING	01/02/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4719860	17	PL24	CHECK DRY RISERS	27/01/2017 11:50:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4711275	13	NE5	Locks and Fittings: Door closer; broken; external door; timber door; DOOR LEADING TO THE FOOR ON THE 9TH FLOOR; overhead door closer; Fair wear and tear REPORTED BY NO	26/01/2017 13:39:29	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4711229	56	H3	Communal: Door Entry System; main entrance intercom unit; buzzers not working; Block affected; PORTHILL COURT, AB25 1BH; Fair wear and tear NO BUZZERS WORKING ON THE TOP FLOOR.PUSH ANY BUTTON WILL OPEN THE DOOR.REPORTED BY OF Communal: CCTV Cameras; No cctv on the 9th floor.	26/01/2017 13:37:25	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4703178	56	E4	Reported by resident . There was work done last year and the CCTV was covered up. Since then it has not been put back into operation. Please phone tenant to advise.	25/01/2017 13:13:54	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4680029	22	PL24	ADL - FIT NEW INDICATOR SYSTEM AS REQUIRED	23/01/2017 12:35:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4668622	56	H3	GENERAL AND TECHNICAL - COMMUNAL STAIRS - REPLACE MISSING NOSING AT TOP STEP OF COMMUNAL STAIRS LEADING TO 1ST FLOOR	20/01/2017 09:16:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4654523	56	E4	LANES FOR DRAINS - CLEAR CHOCKED DRAINS COMING FROM ROOF TO GROUND FLOOR , CONTACT (LANES SUPERVISOR)	18/01/2017 12:40:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4646602	56	E4	ADL - Communal: Lifts; Block Affected; ; Lift serves all floors; THE BUTTON THAT YOU PRESS TO CALL BOTH LIFTS ON GROUND FLOOR IS BROKEN REPORTED BY NO	17/01/2017 13:53:26	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4630312	56	E4OOH	Communal: Door Entry System; Cannot hear visitors; Check intercom and handset; Block affected; main; Fair wear and tear All properties.	14/01/2017 11:55:17	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4626555	18	E4	Communal: Refuse Chute blocked; floor; 7TH FLOOR REPORTED BY FROM HSING CENTRAL 3	13/01/2017 12:41:36	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4609117	56	U24	Communal: Door Entry System; main entrance intercom unit; buzzers not working; Block affected; Porthill Court; Fair wear and tear Buzzers, intercom and door locks not operating. Reported by tenant	11/01/2017 11:46:09	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4564548	56	H3	Communal: Door Entry System; main entrance intercom unit; press any button at the front door and the door unlocks; Block affected; ; Fair wear and tear Reported via RepairFinder by tenant	04/01/2017 16:12:35	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4556137	56	PL24	FACILITIES - CLEAN BLOOD STAINED CARPET ON 1ST FLOOR OUTSIDE NUMBER	04/01/2017 09:00:03	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4554355	56	E4OOH	BUTTON ON THE LIFTS ARE BROKEN - REPORTED BY FLAT - CONTACT NUMBER	03/01/2017 09:45:03	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4588131	22	E4OOH	BUTTON ON THE LIFTS ARE BROKEN - REPORTED BY FLAT - CONTACT NUMBER	03/01/2017 09:45:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4519364	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/01/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4516910	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	01/01/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4514800	20	PL24	GENERATOR MAINTENANCE	01/01/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4513972	56	PL24	ADL - LIFTS MONTH SERV FACT	01/01/2017	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4548248	50	I3	FROM NUMBER CONTACT NUMBER - WOULD LIKE TO SPEAK WITH THE IOW RE BLOOD ON THE CARPET ON THE LANDING OWNERS ON THAT FLOOR	29/12/2016 10:40:26	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4542013	25	U24	FOLLOW ON JOB: For OOH Temporary repairs; Original Job No.; 4542006; REPLACE SINGLE GLAZING WINDOW ON 9TH FLOOR COMMUNAL LANDING NEXT TO LIFT; IF NOT REPAIRABLE THEN PLEASE RENEW; Fair wear and tear	26/12/2016 12:22:40	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4542006	13	E4OOH	Glazing: Single glazing; 9TH FLOOR LANDING NEXT TO LIFT; clear glass; unknown frame type; smashed pane; Fair wear and tear	26/12/2016 12:19:11	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D

4541877	25	H3	FOLLOW ON JOB: For OOH Temporary repairs; Original Job No.; 4541845; GLAZIER TO REGLAZE WINDOW BOARDED UP BY JOINER; IF NOT REPAIRABLE THEN PLEASE RENEW; Fair wear and tear	26/12/2016 10:58:26	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4541845	13	E4OOH	Police: Board up Window; COMMUNAL LANDING NEAR NO ; BOARDED TO A MINIMUM OF 18MM THICKNESS AND FIXED WITH SECURITY SCREWS	26/12/2016 10:53:52	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4541820	56	E4OOH	Specialist Cleaning: Specialist Cleaning Required	26/12/2016 10:46:24	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4534773	12	NE5	Communal: Communal lighting; Communal lighting - not working; 5TH FLOOR ON THE STAIRWELL; Only one light affected; Floor(s) affected; ; Fair wear and tear REPORTED BY ORBIS	22/12/2016 16:18:27	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4533459	22	PL24	PAINT BOTH PITS AND MOTOR ROOM FLOOR AFTER WATER DAMAGE (EXTERNAL CONTRACTOR DAMN TO BE RECHARGED)	22/12/2016 13:47:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4529187	22	PL24	REPAIR/REPLACE FAULTY INDICATOR AFTER WATER DAMAGE - CHARGES TO DAMN	22/12/2016 07:58:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4529162	22	PL24	PUMP OUT LIFT PITS AS PER	22/12/2016 07:56:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4516780	56	U24	Communal: TV reception/Aerial; Missing All Channels; Problem occurs all the time; No signal; If fault found to be from Tenant's (TV, aerial lead or freeview box); Contractor to inform ACC of details and if tenant rechargeable on invoice Reported by tenant	21/12/2016 09:23:16	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4508940	11	E4	(NO MATERIALS USED - JS) 2 X BROKEN/VANDALISED WIN	20/12/2016 11:47:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4508932	25	E4	2 X BROKEN/VANDALISED WINDOWS. GRND FLOOR AT BOTTOM STAIRCASE. 7TH FLOOR NEXT TO LIFT. REPORTED BY FROM THE 7TH FLOOR.	20/12/2016 11:46:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4508146	13	U24	7TH FLOOR COMMUNAL CUPBOARD DOOR - MEET ON SITE	20/12/2016 10:54:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4500789	12	PL24	FAO - SUPPLY AND FIT DRY RUN WIRES TO PUMPS AS PER	19/12/2016 09:34:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4497610	56	E4OOH	Blood in lifts and door entry system. Reported by	17/12/2016 14:42:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4497530	13	E4OOH	2 X BROKEN/VANDALISED WINDOWS. GRND FLOOR AT BOTTOM STAIRCASE. 7TH FLOOR NEXT TO LIFT. REPORTED BY FROM THE 7TH FLOOR.	17/12/2016 14:06:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4482821	56	U24	Communal: TV reception/Aerial; Missing All Channels; Problem occurs all the time; REPORTED BY IN FLAT ; If fault found to be from Tenant's (TV, aerial lead or freeview box); Contractor to inform ACC of details and if tenant rechargeable on inv	14/12/2016 15:55:03	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4482420	17	PL24	CHECK DRY RISERS	14/12/2016 15:29:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4477669	56	E4	Specialist Cleaning: Specialist Cleaning Required; smelly rubbish/waste at 7th floor chute room reported via email by	14/12/2016 09:40:33	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4475799	56	H3	Communal: Door Entry System; main entrance intercom unit; buzzers not working; Block affected; whole building; Fair wear and tear REPORTED BY AT NUMBER . HE'S CHECKED WITH SEVERAL NEIGHBOURS AND NOBODY CAN BE CONTACTED BY T	13/12/2016 18:10:58	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4474097	22	PL24	SUPPLY AND FIT SAFETY EDGES AS PER (EXTERNAL CONTRACTOR DAMN TO COVER COSTS)	13/12/2016 14:42:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4466426	13	NE5	COMMUNAL - DOOR RETURN ON THE FIRE DOOR LEADING TO THE NORTH ROOF FLATS IS CATCHING - REPAIR	12/12/2016 13:19:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4465408	56	E4	R B WILSON - REPAIR INTERCOM DUE TO WATER DAMAGE (EXTERNAL CONTRACTOR DAMN TO COVER COSTS)	12/12/2016 11:14:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4465253	22	E4OOH	CONFIRMATION WORK DONE 11/12/16. Communal: Lifts;	12/12/2016 11:00:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4465197	56	E4	AB TECH - CHECK OVER ALL SATILITE EQUIPMENT THROUGHOUT BUILDING AFTER BAD WATER PEN (ESPECIALLY 7TH FLOOR LIFT LANDING CUPBOARD) /NW (EXTERNAL CONTRACTOR DAMN TO COVER COSTS)	12/12/2016 10:56:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4464436	17	E4	Pipes: Water pressure and supply; No water supply; Properties throughout Multi Storey affected Water is off altogether. Reported by No.	12/12/2016 10:01:48	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4464250	12	E4	NO COMMUNAL LIGHTS THROUGHOUT BUILDING AFTER BAD WATER PEN OVER WEEKEND (EXTERNAL CONTRACTOR DAMN TO COVER COSTS)	12/12/2016 09:46:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4462654	22	PL24	FOLLOW ON FROM E4OOH - CHECK OVER AND REPAIR LIFTS AS REQUIRED AFTER WATER LEAK (EXTERNAL CONTRACTOR DAMN TO COVER COSTS)	12/12/2016 07:55:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4462220	56	E4OOH	Communal: Lifts; Block Affected; Porthill Court; Both Lifts; Major water leak causing water to leak through lifts and lift electricals. Reported by chair of Resident's Association (EXTERNAL CONTRACTOR DAMN TO COVER COSTS)	11/12/2016 17:19:34	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4462213	56	E4OOH	CLEANING REQUIRED IN CORRIDORS AFTER FLOOD DAMAGE. REPORTED BY ON CALL PLUMBER (EXTERNAL CONTRACTOR DAMN TO COVER COSTS)	11/12/2016 17:18:54	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4462189	56	E4OOH	Specialist Cleaning: Specialist Cleaning Required;	11/12/2016 17:11:18	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4462005	17	E4OOH	No cold water supply advised by several tenants ca	11/12/2016 14:12:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4461717	17	E4OOH	Pipes: Water pipe - leaking or burst; Yes - Opera	11/12/2016 11:02:10	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4461611	22	E4OOH	Communal: Lifts; Block Affected; PORTHILL COURT;	11/12/2016 09:42:30	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4461467	56	E4OOH	FLOODING ATTHE COMMUNAL AREA OF PORTHILL COURT. RE	11/12/2016 07:22:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D

4445632	56	E4OOH	Specialist Cleaning: Specialist Cleaning Required;	07/12/2016 16:24:15	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4428402	12	NE5	Communal: Communal lighting; Communal lighting - not working; DIRECTLY OUTSIDE FLAT ON 1ST FLOOR; Only one light affected; Floor(s) affected; 1ST FLOOR REPORTED BY AT FLAT ; Fair wear and tear	05/12/2016 14:06:45	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4420202	56	E4OOH	Communal: Door Entry System; full lockout/in; Block affected; 9th floor security door; Fair wear and tear	03/12/2016 17:00:59	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4420097	56	H3	Communal: Door Entry System; main entrance intercom unit; door not locking; Block affected; .; Fair wear and tear	03/12/2016 16:01:23	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4407792	56	H3	NEW SET OF FIRE PANEL KEYS ARE NEEDED IN FIRE BOX AS THEY HAVE GONE MISSING AS PER	01/12/2016 11:14:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4363480	17	PL24	DRAIN CHECKS IN LAUNDRY AND TANK ROOM	01/12/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4357990	20	PL24	GENERATOR MAINTENANCE	01/12/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4357100	56	PL24	ADL - LIFTS MONTH SERV FACT	01/12/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4402635	56	PL24	EMERGENCY LIGHTING MONTHLY SERVICE	01/12/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4404544	25	U24	Glazing: Single glazing; 1ST FLOOR BACK STAIRS DOOR LOWER PANEL ; toughened glass; wooden; cracked pane; Vandalism AS PER (HOUSING CENTRAL 3)	30/11/2016 17:04:30	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4392155	56	U24	Communal: TV reception/Aerial; Missing All Channels; Problem occurs all the time; no signal; If fault found to be from Tenant's (TV, aerial lead or freeview box); Contractor to inform ACC of details and if tenant rechargeable on invoice Reported by	29/11/2016 13:16:56	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4332577	18	R10	CLEAR AND SPREAD SALT OVER ALL OUTLETS ON ROOF	21/11/2016 10:25:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4328940	12	I3	Communal: Smoke detector; unknown detector type; HALLWAY REQUESTED BY FIRE SERVICE TO RESET ALARM - REF 10721	20/11/2016 17:14:26	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4326773	12	U24	Electric power: No lights or power; light circuit only affected; Fair wear and tear	19/11/2016 10:28:56	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4324208	12	H3	1ST FLOOR STAIRWELL LIGHT OUT - REPAIR AS REQUIRED	18/11/2016 14:40:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4292678	12	E4OOH	ALL LIGHTS OUT EXCEPT TOP FLOOR, REPORTED BY ORBIS	14/11/2016 15:13:43	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4279643	12	NE5	Communal: Communal lighting; Communal lighting - not working; 3rd floor at stairs; 4th floor at stairs; Various lights throughout affected; Floor(s) affected; .; Fair wear and tear Reported by ORBIS	11/11/2016 11:32:37	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4267301	13	PL24	FIT ONLY KEY SAFE FOR CLEANING COMPANY AT DESIGNATED LOCATION.	10/11/2016 07:24:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4235441	13	E4OOH	TO ASSIST SPARKY TO GET ACCESS - JOB NUMBER 4234864	06/11/2016 12:30:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4234864	12	E4OOH	Communal: Communal lighting; Communal lighting - not working; THROUGHOUT; ALL lights out; Fair wear and tear REPORTED BY FLAT	06/11/2016 08:49:54	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4224456	17	U24	CHECK DRY RISERS	03/11/2016 16:03:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4156490	20	PL24	GENERATOR MAINTENANCE	01/11/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4157991	56	PL24	ADL - FAO - LIFTS MONTH SERV FACT	01/11/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4160995	56	PL90	EMERGENCY LIGHTING MONTHLY SERVICE	01/11/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4186995	56	E4	Specialist Cleaning: Specialist Cleaning Required; Vomit in left hand lift. Reported by flat - if no entry to building buzz.	28/10/2016 10:59:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4182373	56	H3	- SUPPLY 10 COPIES OF PORTHILL COURT CHUTE ROOM KEY	27/10/2016 15:30:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4152954	13	R10	REPLACE CLEANING CUPBOARD LOCK AS NO KEYS FOR DOOR	24/10/2016 13:09:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4110767	22	E4	Communal: Lifts; Block Affected; Porthill Court; L	17/10/2016 12:55:55	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4068667	18	E4	Communal: Refuse Chute blocked; floor; Unknown Reported by from Orbis	10/10/2016 10:53:55	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4061693	12	NE5	Communal: Communal lighting; Communal lighting - broken; 7th Floor; fluorescent fitting; tube; Only one light affected; Floor(s) affected; 7th; Fair wear and tear Reported by from Orbis	07/10/2016 11:18:24	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
4029047	17	PL24	CHECK DRY RISERS	03/10/2016 13:48:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3980130	20	PL24	GENERATOR MAINTENANCE	01/10/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3981856	56	PL90	EMERGENCY LIGHTING MONTHLY SERVICE	01/10/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3979334	56	PL24	ADL LIFTS MONTH SERV FACT	01/10/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3995049	56	H3	Communal: Door Entry System; main entrance intercom unit; intercom not working; Block affected; Porthill Court; Fair wear and tear Intercom stuck on and wont reset. Reported by number	27/09/2016 16:32:50	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3989855	56	PL24	DAMM - WATER TANKS - GROUND FLOOR + TOP FLOOR - RENEW - OWNERS RECHARGE	27/09/2016 09:56:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D

3985314	13	NE5	Unspecified: Repair as described; Cleaning Cupboard Door; Ground Floor; wood.; Lock on door broken.; ; ; ; IF NOT REPAIRABLE THEN PLEASE RENEW; Please advise supervisor of any work revisions; Fair wear and tear Please advise supervisor of any work revi	27/09/2016 08:47:56	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3880571	12	NE5	Communal: Communal lighting; Communal lighting - not working; 5th floor lobby - 4 out of 5 lights out; Multiple lights ir one area; Floor(s) affected; ; Fair wear and tear Reported by tenant , No , tel:	07/09/2016 15:09:54	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3848623	22	E4	Communal: Lifts; Block Affected; ; Lift serves Odd Floors; stuck on 3rd floor REPORTED BY AT ORBIS TEL	01/09/2016 14:16:31	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3848101	17	PL24	CHECK DRY RISERS	01/09/2016 13:34:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3832904	56	PL90	EMERGENCY LIGHTING MONTHLY SERVICE	01/09/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3820591	20	PL24	GENERATOR MAINTENANCE	01/09/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3831019	56	PL24	ADL - LIFTS MONTH SERV FACT	01/09/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3791350	22	E4	Communal: Lifts; Block Affected; ; Lift serves Odd Floors; People are stuck in lift STUCK ON THE FRIST FLOOR - REPORTED BY FLAT CONTACT NUMBER	24/08/2016 08:59:25	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3758623	56	H3	Communal: Door Entry System; flat handset; No sound coming through handset at Fair wear and tear No sound coming through handset at Porthill Court.	17/08/2016 12:13:26	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3717542	12	R10	No material required. LIGHTS - 13 ,11 AND 7 FLOOR - LIGHTS OUT - AS PER EMAIL FROM ORBIS	10/08/2016 08:50:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3623650	20	PL24	GENERATOR MAINTENANCE	01/08/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3624132	12	PL90	PUMP MAINTENANCE	01/08/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3624693	12	PL90	FAN SERVICING	01/08/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3624887	20	PL90	FAN SERVICING	01/08/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3626450	56	PL90	EMERGENCY LIGHTING MONTHLY SERVICE	01/08/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3622671	56	PL24	ADL - LIFTS MONTH SERV FACT	01/08/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3624326	20	PL90	PUMP MAINTENANCE	01/08/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3641980	13	PL24	SIGN - OUTSIDE LIFTS ON 5TH FLOOR - REMOVE + CHANGE NUMBERS TO 33 - 48 -	27/07/2016 09:51:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3621452	22	E4	Communal: Lifts; Block Affected; Porthill Court; Lift serves all floors; Lift out of order reported by (Orbis) tel	25/07/2016 07:40:32	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3611446	56	H3	Communal: CCTV Cameras; Camera 9 - no image; Scots reported by Cllr Hutchison - member's enquiry ME030132 - flat number sign outside of the lifts on the 5th floor Porthill Court says flats 33 to 47 instead of 33 to 48.	21/07/2016 15:19:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3610964	50	I3	Communal: top floor; external door to eight rooftop flats is damaged; handle broken, strike plate damaged. Fair wear and tear. Reported by No.	21/07/2016 14:34:55	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3600700	13	H3	Communal: top floor; external door to eight rooftop flats is damaged; handle broken, strike plate damaged. Fair wear and tear. Reported by No.	20/07/2016 11:17:42	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3598237	17	PL24	CHECK CONDITION OF TANKS - TAKE PHOTOS AND REPORT TO - FAO	20/07/2016 09:42:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3578849	17	PL24	CHECK DRY RISERS	15/07/2016 11:04:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3551595	25	U24	Glazing: Single glazing; 5TH FLOOR LANDING DOOR; toughened glass; unknown frame type; smashed pane; Fair wear and tear REPORTED BY ORBIS	11/07/2016 10:52:52	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3526927	17	PL24	CHECK DRY RISERS	06/07/2016 10:40:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3514335	56	H3	Communal: CCTV Cameras; External cameras at Porthi	04/07/2016 14:03:02	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3470826	56	PL90	EMERGENCY LIGHTING YEARLY SERVICING	01/07/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3469650	56	PL90	EMERGENCY LIGHTING MONTHLY SERVICE	01/07/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3467710	56	PL24	ADL - FAO - LIFTS MONTH SERV FACT	01/07/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3461612	20	PL24	GENERATOR MAINTENANCE	01/07/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3501127	50	I3	ALREADY ATTENDED - OF PORTHILL COUR	30/06/2016 16:06:36	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3456298	14	H3	LEVEL SLAB AT UNDERPASS -	23/06/2016 14:32:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3456234	13	H3	FIT PLY OVER HOLES IN PLASTER WORK AT UNDERPASS ZIP UP SCAFFOLD REQ	23/06/2016 14:27:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3454082	50	I3	CHECK OUT UNDER PASS AS PER FAO	23/06/2016 12:34:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3453113	14	E4	MAKE SAFE COMMUNAL HALLWAY AREA AFTER CEILING COLLAPSED SET UP HERRIS FENCING	23/06/2016 11:25:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3446700	25	E4	Glazing: Single glazing; ENTRY DOOR TO THE TOP FLOOR ; toughened glass; wooden; smashed pane; Fair wear and tear CRIME CHECK REF NO cf01798506616 .reported by OF	22/06/2016 12:57:09	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3433370	18	PL24	CHECK ROOF OF BUILDING ONGOING PROBLEM SEE PHOTOS ACCESS TO ROOF AT 9TH FLOOR	20/06/2016 14:37:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3422779	50	I3	LEAK AT ROOF INTO FLAT	17/06/2016 11:05:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3421800	17	E4	COMMUAL - 7TH FLOOR - THERE IS A LEAK IN THE CEILING JUST BEFORE YOU GO THROUGH THE DOOR FROM THE LIFT LANDING TO THE NORTH CORRIDOR	17/06/2016 10:19:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3368545	17	U24	COMMUNAL VERHANDA STACK CHOKED - LEAKING INTO PRIVATE FLAT NUMBER AND INTO FLAT POSSIBLE OVERFLOW FROM 3RD FLOOR BALCONY	08/06/2016 09:43:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3337618	17	PL24	COMMUNAL VERHANDA STACK CHOKED - CHECK AND REPAIR	02/06/2016 09:01:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3298649	20	PL24	GENERATOR MAINTENANCE	01/06/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D

3302429	56	PL24	F.A.O ADL. LIFTS MONTH SERV FACT	01/06/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3303278	56	PL90	EMERGENCY LIGHTING MONTHLY SERVICE	01/06/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3295969	56	H3	Communal: CCTV Cameras; Camera 4 4 out of position	26/05/2016 11:05:30	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3273900	17	E4	WATER LEAKING AT PORTHILL COURT INTO PRIVATE PROPERTY NO TEL - THINKS IT IS COMING FROM NO BUT SHE IS NOT SURE CAN WE INVESTIGATE PLEASE	23/05/2016 12:17:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3259653	17	PL24	CHECK DRY RISERS	19/05/2016 15:00:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3258868	13	U24	GAIN ACCESS TO ELECTRIC CUPBOARD FOR ELECTRICIAN AND RENEW PADLOCK - KEYS TO GO IN FIREBOX	19/05/2016 14:04:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3256388	12	NE5	LIGHT - LANDING ON 9TH FLOOR - LIGHT OUT OUTSIDE CHUTE ROOM - AS PER EMAIL FROM ORBIS	19/05/2016 11:01:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3238556	20	PL24	CHECK AND CLEAR RUBBISH FROM PUMP ROOM AND LIFT ROOM -	16/05/2016 15:17:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3212549	56	U24	Communal: TV reception/Aerial; Missing All Channels; Problem occurs all the time; No Signal; If fault found to be from Tenant's (TV, aerial lead or freeview box); Contractor to inform ACC of details and if tenant rechargeable on invoice	11/05/2016 13:00:58	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3208333	12	E4	CHECK WATER PUMPS FOR PORTHILL AND SEAMUNT COURT	11/05/2016 07:33:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3208260	12	E4OOH	Communal: Unspecified communal repair; pump room; Seamount court fire room; ; no cold water supply - assist plumber with repair to pump; ; ; ; IF NOT REPAIRABLE THEN PLEASE RENEW; Please advise supervisor of any work revisions; Fair wear and tear	10/05/2016 22:31:59	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3208252	17	E4OOH	Communal: Unspecified communal repair; Water pump; actually located in Seamount and you will need access to the fire panel room.; ; no cold water; ; ; ; IF NOT REPAIRABLE THEN PLEASE RENEW; Please advise supervisor of any work revisions; Fair wear and tear	10/05/2016 22:29:42	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3203984	56	H3	Communal: CCTV Cameras; no image; Scotshield contr	10/05/2016 10:14:40	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3120975	56	PL90	EMERGENCY LIGHTING MONTHLY SERVICE	01/05/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3114875	20	PL24	GENERATOR MAINTENANCE	01/05/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3113381	56	PL24	ADL - LIFTS MONTH SERV FACT	01/05/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3144671	17	PL24	CHECK DRY RISERS	28/04/2016 10:33:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3129079	22	E4	Communal: Lifts; Block Affected; PORTHILL COURT; Lift serves all floors; RIGHT HAND SIDE LIFT STUCK ON 5TH FLOOR REPORTED BY AT ORBIS	26/04/2016 12:25:07	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3109049	17	E4OOH	no water supply to building	23/04/2016 17:28:06	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3092487	13	H3	FIRE DOOR - 7TH FLOOR - SNAPPED OFF - AS PER EMAIL FROM ORBIS	21/04/2016 08:24:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3068040	13	U24	UNDERPASS - REFIT BOARDING TO UNDERPASS AFTER DRAIN SURGEONS	18/04/2016 09:46:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3061038	56	NE5	DRAIN SURGEONS - JET STACK FOR WASTE - STACK AFFECTING FLAT 7 UPWARDS -	15/04/2016 12:51:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3061013	14	NE5	APPT 18/04 AM - MEET DRAIN SURGEONS AT UNDERPASS - FIT ZIP UP SCAFFOLD AT STACK AFFECTING FLAT 7 UPWARDS -	15/04/2016 12:49:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3037762	25	E4	Glazing: Single glazing; 1st floor landing window smashed; clear glass; wooden; smashed pane; Fair wear and tear REPORTED BY AT ORBIS TEL	12/04/2016 10:20:37	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3036617	25	PL24	Communal: Door - damaged; Glazed Panel; Single glazed; internal (landing/ stair); toughened glass (acid etched mark in corner of glass); Vandalism; Crime Ref Num; CS0105560416	12/04/2016 08:42:15	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
3034539	56	H3	Communal: CCTV Cameras; Camera 13 4 chewing gum on	11/04/2016 15:06:34	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2993973	50	I3	DEALING - FOLLOW ON JOB: For OOH Temporar	04/04/2016 22:36:20	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2993726	18	H3	Roofs: Roof - leaking; 7TH FLOOR; flat; Can't contain the leak; above three storey; NO; MEANS OF ACCESS WILL BE REQUIRED - SLATER TO ARRANGE; Fair wear and tear	04/04/2016 19:02:03	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2939089	56	PL90	EMER LIGHT MONTH SERV FACT	02/04/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2981896	56	NE5	R.B. WILSON - SERVICE ENTRY SYSTEM - REPAIR	01/04/2016 14:19:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2980300	17	PL24	CHECK DRY RISERS	01/04/2016 12:47:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2935260	20	PL24	GENERATOR MAINTENANCE	01/04/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2936391	56	PL24	ADL - LIFTS MONTH SERV FACT	01/04/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2960252	56	PL24	ADL - REPLACE CAR INDICATORS TO ANTI VANDAL TYPE - BOTH LIFTS £3800	30/03/2016 08:28:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2945541	56	H3	Communal: Door Entry System; Service button not working reported by RESIDENT ASSOC CHAIRPERSON-	28/03/2016 12:51:12	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2934098	22	E4OOH	Communal: Lifts; Block Affected; Main; Lift serves Odd Floors; Lift stuck on 7th floor.	27/03/2016 09:08:49	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2886285	56	E4	Communal: Door Entry System; main entrance intercom unit; intercom not working; Block affected; Porthill Court; Fair wear and tear	17/03/2016 14:52:06	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2859930	17	PL24	Clir reports the intercom system is not working, buttons not working and no display	14/03/2016 11:26:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2801380	13	NE5	CHECK DRY RISERS	03/03/2016 13:46:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2742060	56	PL90	REAR DOOR BEING BOUNCED OPEN - CAN A DOOR STOP OR DIFFERENT DOOR CLOSER BE USED	02/03/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
			EMER LIGHT MONTH SERV FACT		

2785765	56	PL24	HUTCHEON - CONFIRMATION ORDER - ADDITIONAL EMERGENCY LIGHTING - FEBRUARY 2016 - DAYWORK 859	01/03/2016 14:32:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2738538	56	PL24	ADL -LIFTS MONTH SERV FACT	01/03/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2739517	20	PL24	GENERATOR MAINTENANCE	01/03/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2723146	56	H3	Communal: CCTV Cameras; Camera 1 - no image; Scots	22/02/2016 11:38:44	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2719325	13	H3	APPT 22/02 AM - LIFT FLOORING AT NO.16 FOR PLUMBER -	22/02/2016 07:50:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2715539	17	H3	APPT 22/02 AM - RENEW CAST IRON STACK AT NO. - MASON TO ASSIST -	19/02/2016 14:53:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2715507	14	R10	22/02AM BREAK OUT CONCRETE FOR PLUMBER TO RENEW 4" STACK IN FLAT APPT 19/02 AT 13.00 - MEET ON SITE REGARDING LEAK -	19/02/2016 14:46:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2705201	17	H3		18/02/2016 14:01:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2702458	13	U24	SIDE DOOR BROKEN AT TOP AND ALLOWING ROUGH SLEEPERS TO GAIN ACCESS --18/02/16	18/02/2016 10:29:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2684459	56	H3	Communal: CCTV Cameras; Cameras 1 & 10 - no image;	16/02/2016 10:10:10	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2682155	12	H3	SOME OF THE COMMUNAL LIGHTING NOT WORKING ON 7TH FLOOR - REPORTED BY PORTHILL COURT	15/02/2016 20:41:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2679391	12	U24	CHECK LANDING CUPBOARDS/Loud buzzing/humming noise - unknown source. Particularly noticeable at night. Audible at Nos. and . Reported by tenant tel:	15/02/2016 13:38:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2669466	50	I3	Loud buzzing/humming noise - unknown source. Particularly noticeable at night. Audible at Nos. and Reported by tenant Mr , No.	12/02/2016 16:01:52	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2649475	17	PL24	CHECK DRY RISERS - CHECK IF SMARTWATER SECURITY PAINT HAS BEEN APPLIED AND REPORT TO IF NOT	10/02/2016 13:45:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2642935	56	H3	- SUPPLY 4 COPIES OF MASTER KEY FOR PORTHILL COURT	08/02/2016 16:45:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2642696	22	PL24	SUPPLY ONLY - FIT NEW ROOF TOP GUARD RAILS x2 Communal: TV reception/Aerial; Missing All Channels; Problem occurs all the time; NO SIGNAL; If fault found to be from	08/02/2016 13:19:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2642560	56	U24	Tenant's (TV, aerial lead or freeview box); Contractor to inform ACC of details and if tenant rechargeable on invoice	08/02/2016 11:47:45	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2642527	17	PL24	CHECK DRY RISERS	08/02/2016 11:29:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2642154	17	H3	MEET ON SITE TO DISCUSS WATER PEN FROM PRIVATE FLAT	08/02/2016 07:29:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2641541	11	E4	COMMUNAL SIDE DOOR - METAL DOOR IS BADLY TWISTED AND NOT CATCHING THE MAGNETS - TOP AND THE BOTTOM MAGNETS - REPORTED BY FLAT SEAMOUNT COURT GROUND FLOOR SIDE DOOR ENTRANCE	05/02/2016 12:27:34	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2641251	13	NE5	REFIT PANEL UNDER BUILDING AT RHS OF ENTRANCE - REMOVED BY PLUMBER FOR LEAK - LADDER REQUIRED	05/02/2016 09:29:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2640470	11	PL24	DOOR - FRONT COMUNAL - FIT DRAUGHT EXCLUDER AT FOYER TO PREVENT WATER INGRESS - Communal: Door Entry System; KMA (electric keeper) - repair or renew	04/02/2016 08:40:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2639145	56	E4	Side door kicked in. Police in attendance, please re-secure ASAP. Reported by Orbis	02/02/2016 13:59:24	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2633888	56	PL90	EMER LIGHT MONTH SERV FACT	02/02/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2633202	56	PL24	ADL - FAO - LIFTS MONTH SERV FACT	01/02/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2633273	20	PL24	GENERATOR MAINTENANCE	01/02/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2633337	12	PL24	PUMP MAINTENANCE	01/02/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2633347	20	PL24	PUMP MAINTENANCE	01/02/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2633367	12	PL90	FAN MAINTENANCE	01/02/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2633385	20	PL90	FAN MAINTENANCE	01/02/2016	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2635080	17	R10	CHECKK FOR WATER LEAKING THROUGH BUILDING AND APPEARING AT UNDER PASS AT BOTTOM OF THE BUILDING AFFECTING SIDE NOS 16, 32, 48, 64 & 9, 25, 41, 57 -	27/01/2016 13:45:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2634014	50	I3	ASAP REGARDING COLLAPSED CEILING AT REAR LEFT HAND SIDE OUTSIDE	26/01/2016 11:45:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2633898	18	E4	PART OF THE CANOPY ROOF AT PORTHILL COURT HAS COLLAPSED, REPORTED BY AT ORBIS HER CLEANER IS WORRIED FOR THE SAFETY OF EVERYONE	26/01/2016 11:13:37	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2631349	56	E4	Communal: Door Entry System; KMA (electric keeper) - repair or renew Side door, please secure asap, as per	22/01/2016 11:56:53	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2630476	12	NE5	Communal: Communal lighting; Communal lighting - not working; 2nd floor light in the emergency stairs; Only one light affected; Floor(s) affected; .; Fair wear and tear Reported via e-mail by , Property Factoring Officer, tel:	21/01/2016 11:27:27	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2629421	12	NE5	Communal: Laundry Facilities; Tumble Drier; ALL TUMBLE DRIERS ARE BROKEN EXCEPT FOR THE BLUE COULOURED ONE REPORTED BY OF FLAT , TEL NO	20/01/2016 10:03:59	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2626657	12	NE5	1st floor lights in hall next to emergency stair, both out.	15/01/2016 13:57:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2626656	12	NE5	5th floor emergency stair light is not working.	15/01/2016 13:56:00	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D
2625458	56	H3	Communal: CCTV Cameras; Cameras 1 & 10 - no image;	14/01/2016 10:14:15	ADMIN, PORTHILL COURT, GALLOWGATE, ABERDEEN, AB25 1D