











Building Energy Performance		Scotland						
Energy Performance Certificate	Calculated asset rating using iSBEM v3.5.b [SBEM]	Building type Community/day centre						
	Carbon Neutral							
		A (0 to 15)						
		B (16 to 30)						
		C (31 to 45)						
		D (46 to 60)						
		E (61 to 80)						
		F (81 to 100)						
		G (100+)						
	Current rating		Excellent					
		 E						
Very Poor								
Carbon Dioxide Emissions								
The number refers to the calculated carbon dioxide emissions in terms of kg per m ² of floor area per year		71						
Approximate current energy use per m ² of floor area:		302 kWh/m²						
Main heating fuel: Natural Gas		Building Services: Heating with Nat. Vent.						
Renewable energy source:		Electricity: Grid supplied						
Carbon Dioxide is a greenhouse gas which contributes to climate change. Less Carbon Dioxide emissions from buildings helps the environment.								
Benchmarks								
A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating:		29  B						
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating:		55  D						
Recommendations for the cost-effective improvement (lower cost measures) of the energy performance								
<table border="0" style="width: 100%;"> <tr> <td style="width: 50%;">1. Install loft insulation where possible.</td> <td style="width: 50%;">4. Consider replacing heating boiler plant with high efficiency type.</td> </tr> <tr> <td>2. Create a Maintenance schedule.</td> <td>5. Consider replacing T8 lamps with retrofit T5 conversion kit.</td> </tr> <tr> <td>3. Extend existing heating system to rooms with no heating.</td> <td>6. The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements.</td> </tr> </table>			1. Install loft insulation where possible.	4. Consider replacing heating boiler plant with high efficiency type.	2. Create a Maintenance schedule.	5. Consider replacing T8 lamps with retrofit T5 conversion kit.	3. Extend existing heating system to rooms with no heating.	6. The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements.
1. Install loft insulation where possible.	4. Consider replacing heating boiler plant with high efficiency type.							
2. Create a Maintenance schedule.	5. Consider replacing T8 lamps with retrofit T5 conversion kit.							
3. Extend existing heating system to rooms with no heating.	6. The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements.							

Address: Quarry Centre, Cummings Park Crescent, Aberdeen, AB16 7AS

Conditioned area (m²): 1215

Name of protocol organisation: BRE Global, [BRE-ND-EPC00535]

Date of issue of certificate: 14 Mar 2011 (Valid for a period not exceeding 10 years)

This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.

NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE