











Building Energy Performance		Scotland						
Energy Performance Certificate	Calculated asset rating using iSBEM v3.4.a [SBEM]	Building type Sports centre/leisure centre						
	Current rating							
	Excellent							
		Carbon Neutral						
		A (0 to 15)						
		B (16 to 30)						
		C (31 to 45)						
	D (46 to 60)							
	E (61 to 80)							
	F (81 to 100)							
	G (100+)							
Very Poor								
Carbon Dioxide Emissions								
The number refers to the calculated carbon dioxide emissions in terms of kg per m ² of floor area per year		75						
Approximate current energy use per m ² of floor area:		286 kWh/m²						
Main heating fuel: Natural Gas		Building Services: Heating with Mech. Vent.						
Renewable energy source:		Electricity: Grid supplied						
Carbon Dioxide is a greenhouse gas which contributes to climate change. Less Carbon Dioxide emissions from buildings helps the environment.								
Benchmarks								
A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating:		52  D+						
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating:		56  D						
Recommendations for the cost-effective improvement (lower cost measures) of the energy performance								
<table border="0" style="width: 100%;"> <tr> <td style="width: 50%;">1. Add local occupancy sensor to the lighting system.</td> <td style="width: 50%;">4. Consider replacing T8 lamps with retrofit T5 conversion kit.</td> </tr> <tr> <td>2. Consider installing a ground source heat pump.</td> <td>5. Add local time control to heating system.</td> </tr> <tr> <td>3. Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.</td> <td>6. Consider replacing heating boiler plant with a condensing type.</td> </tr> </table>			1. Add local occupancy sensor to the lighting system.	4. Consider replacing T8 lamps with retrofit T5 conversion kit.	2. Consider installing a ground source heat pump.	5. Add local time control to heating system.	3. Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	6. Consider replacing heating boiler plant with a condensing type.
1. Add local occupancy sensor to the lighting system.	4. Consider replacing T8 lamps with retrofit T5 conversion kit.							
2. Consider installing a ground source heat pump.	5. Add local time control to heating system.							
3. Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	6. Consider replacing heating boiler plant with a condensing type.							

Address: Westburn Tennis Centre, Westburn Park, Westburn Road, Aberdeen, AB25 3
Conditioned area (m²): 2734
Name of protocol organisation: BRE Global, [BRE-ND-EPC00204]
Date of issue of certificate: 22 Oct 2009 (Valid for a period not exceeding 10 years)
 This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.
NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE